


NOTES:

1. WHERE TWO CABLE TO PIPE CONNECTIONS ARE IN THE SAME VICINITY, MAINTAIN A 3-INCH DISTANCE BETWEEN THE CABLE TO PIPE CONNECTIONS.
2. OVERLAP THE EXISTING COATING BY A MINIMUM OF 1/2-INCH.



CABLE TO PIPE CONNECTION

SCALE: NONE

LBNL STANDARD
CABLE TO PIPE CONNECTION DETAIL

UNIVERSITY OF CALIFORNIA LAWRENCE BERKELEY NATIONAL LABORATORY
FACILITIES DIVISION

DRAWN BY	DATE
CHECKED BY	
APPROVED BY	
CAD FILE PATH	
SCALE	NTS
DRAWING NO.	SHEET
U106	
PROJECT NO.	